

3.04.00.25708

NOTE:

- This firmware is for N1C L-Series and 3PL-Series UPS systems only.
- It should only be used for SNMP cards that are version **3.04.##.####** or earlier (3.03, 3.02, 3.01, etc. (see **bold** below)
- It is the latest firmware offered for cards that are version 3.04.##.#### and earlier.
- It cannot be used on cards that have firmware version 3.05.##.#### or 3.06.##.####.

To verify your SNMP cards firmware version, navigate to your UPS network card's IP address followed by "/version.txt"

It should look similar to this:

*KC502 version: KC502_HW_KC502_V3.0 KC502_ **V3.02.01.22053***

hw 15, svn main, trunk

built at Apr 13 2022 06:32:31

SerialNum #####

MAC-1 A0:BB:3E:65:DA:C2

CurrentBaseSoftwareVer KC502_V3.02.01.22053

CurrentSoftwareVer V3.02.01.22053

CurrentConfigToolVer V1.01.00.01501

CurrentConfigVer V2.00.00.10358

2023-04-24 13:40:48